

Pennsylvania Water Environment Federation
PennTEC Annual Technical Conference
June 4, 2013

Altoona Westerly Wastewater Treatment Facility BNR Conversion with Wet Weather Accommodation

Presented by:
Jim Balliet, Secretary/Facilities Planning Director
GWIN, DOBSON & FOREMAN, INC.
Consulting Engineers



Westerly Treatment Facility

- Originally constructed in 1952
- Upstream 125 year old CSO System; “first flush” storage and pumping facility
- Upgraded in 1990
 - Coarse screening and aerated grit removal
 - Complete mix activated sludge, single stage nitrification
 - Final clarification and UV disinfection
 - Equalization storage
- Avg. Daily Flow – 10.8 mgd, Peak Flow – 60 mgd
- Altoona Water Authority – System Owner/Operator

The Chesapeake Bay Strategy

- PA Dept. of Environmental Protection issued new NPDES permits to Altoona with mass annual nutrient load limits
- Average effluent Nitrogen of 14.4 mg/l exceeds future cap load by 80,000 pounds, reduce N discharge by 45%
- Average effluent Phosphorus of 3.0 mg/l exceeds future cap load by 15,000 pounds, reduce P discharge by 55%
- Nutrient Cap Load Target Concentrations:
 - Effluent Nitrogen – 5.0 mg/l
 - Effluent Phosphorus – 0.67 mg/l

Relative Impact




High



Medium



Low



Project Goals

- **Reduce effluent nutrients levels** to ensure regulatory compliance
- **Treat wet weather CSO flows** while preventing washout of process nutrient biomass
- **Use sustainable design** by maximizing use of existing facilities; reduce chemical consumption/waste solids
- **Reduce energy consumption** using gravity flow, efficient NRT process
- **Reduce operating costs** by using energy-efficient equipment and process monitoring & control system
- **Generate nutrient credits** for sale on PA credit market

Evaluation of Alternatives

- Conducted extensive influent testing to characterize waste over full range of flows
- Evaluated existing treatment processes and conducted preliminary screening of various Nutrient Removal Technologies (NRT)
- BioWin process modeling of selected NRT processes with site-specific kinetic rates verified by High F/M testing
- Evaluate wet weather CSO treatment options
- Process evaluation by GDF and Bassett Engineering (process modeling and NRT consultant)


BioWin



**Simulates
biological
processes of
wastewater
treatment plants**

EnviroSim
ASSOCIATES LTD.


Developed By



BioWin Model for NRT Process

Selected Process

- Replace existing screens with fine screens.
- Replace aerated grit system with vortex grit separators
- Convert south EQ tank to two plug flow reactors.
- Convert existing aeration basins to two plug flow reactors.
- Construct fourth secondary clarifier.
- Provide chemical feed systems.
- Upgrade SCADA/instrumentation systems.





**1) Headworks building, 2) Primary Equalization Tanks, 3) Secondary Equalization Tanks
4) BNR Reactors 1 & 2, 5) BNR Reactors 3 & 4, 6) Final Clarifiers, 7) UV Units, 8) Aerobic
Digesters, 9) Digested Solids EQ/Feed Tank, 10) Control Building and Sludge Handling**




Conversion of South Equalization Tank to NRT Reactors

Selected Process

- Provide nutrient removal using four plug NRT reactors.
- Operational flexibility to operate various nutrient removal processes including Bardenpho, MLE, VIP, A20 and Hybrid
- **Step feed high, diluted wet weather CSO flow to last oxic and swing zones to provide secondary (contact stabilization) treatment**

Westerly WWTF

Typical Peak Flow Event (September 27 - October 7, 2011)





Construction of Aeration Tanks Conversion, Distribution Box and Adjacent Step-Feed Channel



Existing Aeration Tanks Converted to NRT Reactors and
Adjacent Step-Feed Channel to Last Oxidic Zone

Hybrid BNR Feature

- Process combines the mixed liquor recycle feature from the VIP process with the Bardenpho process
- Mixed liquor from the final anoxic zone is recycled to the first anaerobic zone
- Lowers the oxidation/reduction potential (ORP) in the anaerobic zone
- Increases phosphorus release and enhances biological phosphorus removal
- Consistently meets P limits without chemical addition



NRT Reactor

Step Feed

- Diverts high wet weather CSO flow to last oxic zone
- Provides biological treatment of all CSO flows via contact stabilization (1-2 hour detention)
- Preserves treatment process sequence (anaerobic, anoxic and aerobic)
- Preserves nitrifiers and maintains N removal during and after high flow events
- Prevents elevated DO concentrations in process.
- Preserves solids washout in clarifiers

Sustainable Design

- Converted existing aeration tank into two plug flow NRT reactors
- Converted existing equalization basin into two plug flow NRT reactors
- Existing tanks were retrofitted with baffle walls to create anaerobic, anoxic and aerobic zones
- Constructed slightly submerged walls with underflow ports
- Located recycle pumps in existing pipe gallery
- Reused air distribution piping, existing flow distribution channels, RAS piping and effluent channels



Retrofitting of Existing Equalization Tank to NRT Reactor



Pipe Gallery Tunnel with Internal Recycle & Air Piping

Operational Flexibility

- Facility can operate in a variety of plug flow NRT removal modes (MLE, Stage 4/5 Bardenpho)
- **Current operation uses Virginia Initiative Plant (VIP) process for step feeding wet weather flow**
- Second anoxic zone is a switch zone (mixer and diffusers) and can operate as an oxic zone during step feed
- VIP process produces lower effluent N during cold weather without the second anoxic zone
- Internal RAS/MLSS/Nutrient recycle streams can draw and pump to multiple zones
- Wet weather CSO flow treated in contact stabilization mode in switch zone/last oxic zone




Switch Zone – Membrane Diffusers (oxic) & Submersible Mixers (anoxic)

BNR Initial Process Parameters

September 2001 – February 2012


			FM			Total		
	SRT	WAS	Ratio	MLSS	RAS	RAS	NR	MLR
	(Days)	(MGD)	(per day)	(mg/L)	(mg/L)	(MGD)	(MGD)	(MGD)
Minimum	2.25	0.07	0.04	1,835	3,700	2.60	1.60	0.90
Average	6.20	0.18	0.11	3,420	8,680	6.20	3.75	2.00
Maximum	14.50	0.34	0.33	4,880	11,950	8.30	4.70	2.50

Westerly WWTF BNR Process - Influent Flow, BOD, and TSS



VIP Process Operation During Wet Weather Flow

Westerly WWTF BNR Process - MLSS, RAS-SS, and %VSS



VIP Process Operation During Wet Weather Flow

Final Clarification

- Project included the addition of a fourth clarifier and upgrades to existing three clarifiers
- Surface overflow rate adequate for 60 mgd peak
- Employed rapid sludge removal via spiral blade sludge collectors
- Full radius skimmers
- Current density baffles (Stamford-type)
- Sludge blanket density meters



Final Clarifiers with Stamford Baffles

SCADA Process Control Features

- Step-feed process flow control
- Mixed liquor and nitrate recycle return rate
- RAS and WAS return rates
- DO control of air supply valves and blower speeds
- NO_3 control of nitrate recycle pumps and methanol
- RP control of mixed liquor recycle
- pH control of caustic soda feed
- NH_4 and PO_4 instruments provide process alarms

Other Facility Improvements

- Fine Screening
- Non-Aerated Vortex Grit Separation
- Final Clarifier Additions and Upgrades
- Ultraviolet Disinfection System
- Aerobic Digester System Upgrades
- Effluent Screw Lift Pumps



New Headworks Building



Headworks Fine Screening



Vortex Grit Separation System (preserve influent carbon)



Ultraviolet Disinfection System



Centrifuge Sludge Dewatering System



60" Diameter Screw Lift Flood Pumps



Energy Efficient Turbo Blowers (high turndown capability)



Chemical Feed and Storage Facilities




Internal Recycle Pumps – Mixed Liquor & Nitrate


BNR Process Results

- Process reduced effluent nitrogen concentration to near 3.0 mg/l with **NO CARBON ADDITION**
- Reduced annual N loading from 240,000 pounds to 70,000 pounds
- Biologically reduced annual P loading from 32,000 to 6,700 pounds with **NO CHEMICAL ADDITION**
- Generated \$300,000 in nutrient credit revenue
- Processed **100% OF WET WEATHER FLOW WITHIN PERMIT LIMITS WITHOUT BNR PROCESS UPSET**
- Annual plant operating costs **REDUCED BY \$110,000**


BNR Process - Effluent Flow, BOD, TSS, and Ammonia



Westerly WWTF BNR Process - Effluent TKN, NOx-N, TN, and TP




Total Effluent Nitrogen Concentration




Monthly TN and TP Effluent Loadings: Actual Results and Permit Goals

Months	Total Nitrogen (TN)		Total Phosphorus (TP)	
	Actual Loading (lbs/mo)	Permit Goal (lbs/mo)	Actual Loading (lbs/mo)	Permit Goal (lbs/mo)
October, 2011	5,163	13,923	654	1,856
November, 2011	4,621	13,474	1,013	1,797
December, 2011	6,086	13,923	343	1,856
January, 2012	7,682	13,923	472	1,856
February, 2012	5,893	13,025	322	1,737
March, 2012	5,011	13,923	537	1,856
April, 2012	5,209	13,474	683	1,797
May, 2012	5,251	13,923	2,175	1,856
June, 2012	4,302	13,474	768	1,797
Total	49,218	123,062	6,967	16,408
Average	5,469	13,673	774	1,823
% Below the Goal	60%		58%	


Annual Total Nitrogen Effluent Loading



Annual Total Phosphorus Effluent Loading



Westerly WWTF - Monthly Average O&M Costs



WESTERLY WASTEWATER TREATMENT FACILITY BNR UPGRADE

2013 Superior Achievement Award





Questions/Discussion